

Date:- 04/03/2024

**Corrigendum to the Bids Request for proposal for Non comprehensive Annual Maintenance Contract of existing CCTV & Integrated Fire cum Burglar Alarm systems and new installation of CCTV & Alarm System at the Bank Branches under Hyderabad Zone for three years**

The Pre-Bid meeting was held on 27/02/2024 on the subject matter and the following are the replies / details to the respective points raised in the meeting.

Sl.No	Page No	Point / Section	Main Section Name	Existing clause	Modification to the Clause.
01	56 - 59	Annexure - 9	Part II	Rate and Models of Alarm System and CCTV	Kindly see revised Annexure - 9 Format
02	4	Allotment of Work	Terms and conditions of the Request for Proposal	<p><b>Price bids of eligible bidders would be comparatively evaluated &amp; lowest bid (L-1) would be decided on the basis of price quoted by bidders in Price Bid- Part 1, Part-2 and Part 3).</b> Work would be allotted to lowest (L-1) bidder; bank may distribute the work among other eligible bidder/s (CCTV/Alarm Systems separately or state wise branches i.e. AP states branches and Telangana states branches at L-I Rates) at the lowest rate. In that case major share of work would be allotted to lowest bidder. Bank reserves the right to negotiate with lowest bidder.</p>	<p><b>Price bids of eligible bidders would be comparatively evaluated &amp; lowest bid (L-1) would be decided on the basis of price quoted by bidders in Price Bid- Part 1, Part-2 and Part 3).</b> Work would be allotted to lowest (L-1) bidder; bank may distribute the work among other eligible bidder/s (CCTV/Alarm Systems separately or state wise branches i.e. AP states branches and Telangana states branches at L-I Rates) at the lowest rate. In that case major share of work would be allotted to lowest bidder. Bank reserves the right to negotiate with lowest bidder.</p> <p>In case the selected L1 Bidder fails to execute the work/agreements with bank within 15 (fifteen) days from date of communication of being selected as L1Bidder, the bank shall be at liberty to allot work with L2 Bidder without assigning any reason and without any cost and /or compensation thereof.</p>

UCO Bank, Zonal Office, 8-2-624, Road no-10, Banjara Hills, Hyderabad,  
Email:zohybd.sec@ucobank.co.in; Contact: 04023322345

Follow UCO Bank onTwitter:UCOBankOfficial; Facebook:Official.UCOBank; Instagram:Official.ucobank

LinkedIn:UCO BANK; You Tube:UCO Bank Official





**Annexure-9 PRICE BID: PART- 1**
**Rates & Models for Alarm System:-**

SN	Items with 1 years warranty- CE/FCC/UL/ BIS Certified	Model No. With specification \$	Qty-(A)	Unit Rates- (B)#	Applicable Taxes (C)	Total A*(B+C)
01	Security alarm Panel with Auto dialer 12+1 Zone fully programmable. Compatible with GSM / IP/ PSTN communicators and on board LCD display with inbuilt SMPS, Enclosure and battery option (12 Volt 7Amp)	12+1 Zone:	10			
02	Supply & install of TCP/ IP Communicator for CMS and remote Configuration		1			
03	Smoke sensor		30			
04	Heat Detector		10			
05	Magnetic contact (C.E. Certified)		25			
06	PIR sensor (C.E. Certified)		30			
07	Vibration Sensors		10			
08	Shutter contact sensors		10			
09	Panic switch		100			
10	Hooter		20			
11	Motorized Siren		10			
12	12V Battery- 7AH	Exide/ equalent	10			
13	MCP		10			
14	Response Indicator		10			
15	Cabling – FRLS PER METRES(in PVC Conduit)- Preferably Polycab/Finolax		2000			
16	Cabling – in PVC Conduit pipe Preferably Polycab/Finolax		2000			
17	Shifting of Alarm Panel within same premises		10			
18	Shifting of Alarm Panel in other premises		10			
19	<b>Total cost of all above items</b>			<b>Grand Total=</b>		

**Grand Total in Words:**

\$ Generally available products in the local market for all vendors

**Annexure-9: PART-2**
**Rates & Models for CCTV System:-**

SN	Items with 1 years warranty- CE/FCC/UL/ BIS Certified	MAKE/MODEL with specification \$	Qty- (A)	UNIT # RATE- (B)	Applicable Taxes	Total- A*( B+C)
01	16 Channel Standalone DVR: 8 SATA port and 4 SATA Port:	8 SATA port	1	Rs.		
		4 SATA port	2	Rs.		
02	8 Channel Standalone DVR: 4 SATA port and 2 SATA Port	4 SATA port	1	Rs.		
		2 SATA port	20	Rs.		
03	4 Channel ATM DVR with built in 90 days recording provision as per the technical Compliance sheet along with Hard Disk: Single SATA Port		1			
	4 Channel DVR with built in 180 days recording provision as per the technical Compliance sheet:	2 SATA PORT	10			
		1 SATA PORT	10			
04	19" and 24" TV Monitor with	19":	5	Rs.		

UCO Bank, Zonal Office, 8-2-624, Road no-10, Banjara Hills, Hyderabad,

Email:zohybd.sec@ucobank.co.in; Contact: 04023322345

**Follow UCO Bank on Twitter:**UCOBANKOfficial; **Facebook:**Official.UCOBank; **Instagram:**Official.UCOBank;

**LinkedIn:**UCO BANK; **You Tube:**UCO Bank Official





	spot/auxillary input: LG/ SAMSUNG	24":	5	Rs.		
05	Veri focal dome IR camera:		50			
06	Veri focal bullet IR camera:		50			
	Pin hole Camera		10			
07	720P HD dome camera,1/4" CMOS,720P (1000 TVL), 3.6 mm, 24 IR LED, 20m		10			
08	720P HD Bullet camera,1/4" CMOS,720P (1000 TVL), 3.6 mm, 24 IR LED, 20m		10			
09	2Mega Pixel IP IR Dome camera with facility of inbuilt recording covering distance of 30 meters		60			
10	2Mega Pixel IP IR Bullet camera with facility of inbuilt recording covering distance of 30 meters		20			
11	64 GB High speed Micro HD Card		10			
12	2 TB Hard Disk		10			
	4 TB Hard Disk		40			
13	6 TB Hard Disk		10			
14	8 TB Hard Disk		5			
15	DVR 4 U Rack		10			
16	RG-6 Video Coaxial Cable (ISI Marked) Preferably Polycab/Finolax		2000			
17	2 Core 14 stand power cable in PVC Conduit pipe Preferably Polycab/Finolax		2000			
18	HDMI CABLE		50			
19	VGA Cable		50			
20	SITC of RG6 Video Cable		50			
21	SITC of 2 Core x 1.5 sq. mm. Power Cable		50			
22	Wireless mouse		10			
23	Power supply , 12V, 6 AMP		40			
24	Power supply for DVR		10			
25	Power supply , 12V, 10 AMP		20			
26	Shifting of CCTV System within same premises		2			
27	Shifting of CCTV System in other premises		2			
28	Cat 6 Cable ( 5 Mtrs)		50			
29	Buy back rate of existing Alarm System (less this amount)		-10			
30	<b>Total Cost of all above items</b>		<b>Grand total Price =</b>			

**Grand Total in Words:**

**\$ Generally available Products in the local market for all vendors**

**Part -3**

SL NO	ITEM DESCRIPTION( The Make & Model should not vary with above mentioned tables)	Required indicative Quantity.(A)	UNIT RATE (RS.)(B)	Applicable Taxes( C )	Total Cost A*(B+C)
01	Supply , Installation and Maintenance of 8 Channel DVR( 2 SATA) along with 4 T.B Hard Disk, Cameras – 8 Nos( HD Verifocal Dome – 3 Nos , HD Fixed	15			

UCO Bank, Zonal Office, 8-2-624, Road no-10, Banjara Hills, Hyderabad,

Email:zohybd.sec@ucobank.co.in; Contact: 04023322345

Follow UCO Bank on Twitter:UCOBANKOfficial; Facebook:Official.UCOBank; Instagram:Official.UCOBank

LinkedIn:UCO BANK; You Tube:UCO Bank Official





	Dome – 3 Nos , HD Verifocal Bullet – 2 Nos ) , cable with conduit pipe(200 Mtrs) , 4 U rack, Mouse, Monitor ( 22" Inch) and any other items required for installation of CCTV Surveillance System at Branch( Preferably HIKVISION/DAHUA/CP Plus or equivalent). No other charges will be borne by bank.				
02	Supply , Installation and Maintenance of 4 Channel DVR(( 2 SATA) along with 4 T.B Hard Disk, Cameras – 3 Nos, ( HD Verifocal Dome – 2 Nos , HD Fixed Dome – 2 Nos ) cable(50 Mtrs) with conduit pipe , 4 U rack, Mouse, Monitor ( 22" Inch) and any other items required for installation of CCTV Surveillance System at Branch( Preferably HIKVISION/DAHUA/ CP Plus or equivalent). No other charges will be borne by bank.	60			
03	Supply, Installation and Maintenance of 2 MP IP, IR Dome Camera with SD Card Support & (Audio Recording Option & motion Detection) + 64 GB Surveillance SD card + Power Adaptor + VGA cable(10 Mtrs) + 2 Core 14-strand Power Cable in PVC Conduit Pipe(10 Mtrs)+ Cat 6 Cable( 10 – Mtrs) D- Link with PVC + Any other items required for installation of IP camera Surveillance System at Branch (Preferably HIKVISION/DAHUA/ CP or equivalent). No other charges will be borne by Bank.	80			
04	Supply, Installation and Maintenance of Fire cum Burglar Alarm Panel with Battery preferably Securico/ Texiocm/ or equivalent + Cable with PVC Conduit Pipe(200 Mtrs) + Power Adpoter + PIR Sensor – 1Nos + Smoke Sensors – 6 Nos + Panic Switches – 6 Nos+ Heat Sensors- 4 Nos+ Vibration sensor- 1 Nos any other items required for installation of Fire cum Burglar Alarm System at Branch. No other charges will be borne by bank.	15			

UCO Bank, Zonal Office, 8-2-624, Road no-10, Banjara Hills, Hyderabad,

Email:zohybd.sec@ucobank.co.in; Contact: 04023322345

Follow UCO Bank on Twitter:UCOBANKOfficial; Facebook:Official.UCOBank; Instagram:Official.UCOBank

Linked In:UCO BANK; You Tube:UCO Bank Official





05	Supply & Installation of Existing DVRs with housing (4U rack- with 500 D) + Wireless Mouse- ISI marked.	80			
06	Supply & Installation of Existing DVRs with housing (6U rack- with 600 D) + Wireless Mouse- ISI marked.	05			
07	Annual Maintenance Charges for the existing CCTV surveillances system under Hyderabad Zone.	86+1(Zonal Office)			
08	Annual Maintenance Charges for the existing Fire cum Burglar Alarm system under Hyderabad Zone.	86+1(Zonal Office)			
	Total Cost				
09	Total cost In words:				
10	Grand Total ( In figures Part-1+ Part-2 + Part-3)				
11	Grand Total ( In words)				

Signature & Seal of the Bidder

Date:

**Addendums to the Bids for Providing Request for proposal for Non comprehensive Annual Maintenance Contract of existing CCTV & Integrated Fire cum Burglar Alarm systems and new installation of CCTV & Alarm System at the Bank Branches under Hyderabad Zone for three years**

Sl.No	Page No	Point / Section	Main Section Name	Additional Point.
01	7	13. Cost of RFP:	Rs. Rs.1000/- (Rupees One Thousand only) payable by Pay order / Demand draft favouring UCO Bank, and payable at Hyderabad.	Rs. Rs.1000/- (Rupees One Thousand only) payable by Pay order / Demand draft favouring UCO Bank, and payable at Hyderabad. <b>In case the bidder is exempted by Govt. order, need to provide certification of exemption proof.</b>
02	7	13 a	Earnest Money	<b>Earnest money deposit:-</b> Bidder has to provide earnest money deposit of Rs. 10000/- ( Ten thousand) in the form of Demand draft (DD) in favour of UCO Bank Zonal Office,

UCO Bank, Zonal Office, 8-2-624, Road no-10, Banjara Hills, Hyderabad,

Email:zohybd.sec@ucobank.co.in; Contact: 04023322345

Follow UCO Bank on Twitter:UCOBANKOfficial; Facebook:Official.UCOBank; Instagram:Official.ucobank

LinkedIn:UCO BANK; You Tube:UCO Bank Official





				Hyderabad along with tender document(Part-I bid). In case the bidder is exempted by Govt. order, need to provide an undertaking on non-judicial stamp stating that he/ they will not refuse to execute the purchase order/ contract if awarded by bank. EMD is liable to be forfeited in the event of: <ul style="list-style-type: none"> <li>a) Revocation of the tender or increasing the rates after opening of the tender and before the expiry of the validity of tender.</li> <li>b) Refusal of the bidder/auditor to execute the work or not complying with the contractual terms &amp; conditions after awarding of contract.</li> <li>c) EMD of unsuccessful bidder would be returned.</li> </ul>
03	4	6a	Payment Terms	Payment will be made by respective branch against invoice after successful completion job. Zonal Office will pay only AMC on half yearly basis subject on submission of mandatory visits reports. The Statutory deductions like TDS & GST as per Rule.

**Quarries & Clarifications to the Bids for Providing Request for proposal for Non comprehensive Annual Maintenance Contract of existing CCTV & Integrated Fire cum Burglar Alarm systems and new installation of CCTV & Alarm System at the Bank Branches under Hyderabad Zone for three years**

Pre-Bid Queries					
Sr. No.	Page No.	Tender Clause No.	Tender Clause	Query	Reply
1	58	Package Cost Point No. 1	8 Channel CCTV System	Please mention as Below:- 1. Nos. of Dome 2. Nos. of Bullet 3. Fix or Varifocal Camera 4. Monitor 19" or 24"	Please refer Annexure 9 revised format.
2	58	Package Cost Point No. 2	4 Channel CCTV System	Please mention as Below:- 1. Nos. of Dome 2. Nos. of Bullet 3. Fix or Varifocal Camera 4. Monitor 19" or 24"	Please refer Annexure 9 revised format.

UCO Bank, Zonal Office, 8-2-624, Road no-10, Banjara Hills, Hyderabad,  
Email:zohybd.sec@ucobank.co.in; Contact: 04023322345

Follow UCO Bank on Twitter:UCOBANKOfficial; Facebook:Official.UCOBank; Instagram:Official.UCOBank;  
LinkedIn:UCO BANK; You Tube:UCO Bank Official





3	59	Package Cost Point No. 4	Fire cum Burglar Alarm System	Please mention nos. of meters of cable with PVC conduit pipe.	Please refer Annexure 9 revised format.
4	07	Cost of RFP and EMD point No 13 & 13a	Rs.1000/- (Rupees One Thousand only) payable by Pay order / Demand draft favouring UCO Bank, and payable at Hyderabad.	Exemption of Tender Cost and EMD to NSIC Registered Vendors under MSME Scheme.	On submission of exemption certificate from MSME, it will be considered.
5	58	Package Cost Point No. 2	4 Channel CCTV System	4 Channel DVR 2 SATA is not available in regular basis from the OEMs	As per OEM information 2 SATA is available in the Market. No Change in the specifications.
6	56	Annexure 9 Part .1 point no - 09	Flame Detectors	Flame Detector specification is not mentioned. No bank is using the detector except Union Bank of India.	Please refer Annexure 9 revised format.
7	39	Appendix 2 , Smoke Sensor and Head Sensor	Specifications	Smoke Detectors specifications mentioned in the tender are for Addressable Smoke detector whereas the panel being used is conventional.	No change in the specification.
8	57	Annexure – 9	Rate and Models for CCTV	Cat-6 cable in line item is not mentioned in the Price bid	Please refer Annexure 9 revised format.
9	57	Annexure – 9	Rate and Models for CCTV	POE Switch for connecting the IP cameras to DVR is not mentioned in the Price Bid and its specifications also to be included.	At present not required.
10	2	Point No.9	Vendor should have supplied CCTV and Alarm systems to 02 PSU Banks (minimum value should be not less than 20 Lacs in PSU Banks in financial year either in India in year (2023-24).	We would like your kind consideration and Request Amendment of Pg 2 Point 9 , Whereas , the tender specifies the following criteria wherein the bidder should have "worked " with TWO PSU banks on similar projects	No Change in the point.

UCO Bank, Zonal Office, 8-2-624, Road no-10, Banjara Hills, Hyderabad,

Email:zohybd.sec@ucobank.co.in; Contact: 04023322345

Follow UCO Bank on Twitter: [UCOBANKOfficial](#); Facebook: [Official.UCOBank](#); Instagram: [Official.UCOBank](#)

LinkedIn: [UCO BANK](#); You Tube: [UCO Bank Official](#)





11	57	Annexure – 9	Rate and Models for CCTV	6 U 600 depth rack for 16 channel 8 sata DVR	Please refer Annexure 9 revised format.
12	56	Annexure -9	Rate and Models for Alarm System.	Brands not specified for alarm system, and product should not be proprietary, should be available in the open market.	Preferably Securico, Hikvision, texicom and equivalent.
13	57	Annexure – 9	Rate and Models for CCTV	HDMI and VGA cable length not mentioned	10 Mtrs for each.
14	4	Payment Terms	Bid Documents	Whether the payment will be done from the Zonal office or Branches.	Please refer Addendums point No-3



UCO Bank, Zonal Office, 8-2-624, Road no-10, Banjara Hills, Hyderabad,  
Email:zohybd.sec@ucobank.co.in; Contact: 04023322345

Follow UCO Bank on Twitter: [UCOBankOfficial](#); Facebook: [Official.UCOBank](#); Instagram: [Official.ucobank](#);  
LinkedIn: [UCO BANK](#); You Tube: [UCO Bank Official](#)