



Corrigendum

Dt-13/04/2021

Ref No- i) e-Tender No-UCO/SEC/HO/2021/179 dated 31/03/2021.

ii) e-Tender No-UCO/SEC/HO/2021/180 dated 31/03/2021

Subsequent to Pre-bid meeting with the representatives of participating vendors held on 12/04/2021, at 11.30 hrs at Central Security Dept., Head Office, UCO Bank, 10, BTM Sarani, Kolkata-01, as per schedule given in the tenders under reference, as per queries raised by all vendors, the following amendments have been made in both Tenders documents -

SI No	Query Raised	Proposed Changes/ Amendment
	<u>Tender No-UCO/SEC/HO/2021/179 & 180 dated 31/03/2021.</u>	
1.	Clause- 5.3 (for both) Installation & Commissioning-Time given 8(eight) weeks.	Installation & Commissioning Time may be extended up to 10 (Ten) weeks after handing over the site to selected L-1 vendor.
2.	Part-IV-Scope of Work (for both) Submission of SLD- Not Mentioned	A sub-clause will be inserted that L-1 vendor will submit a Single Line Diagram after installation.
3.	Clause No-1.2- (for both) Contents of Technical Bid-Letter from OEM- Not Mentioned	MAF should be submitted by bidders in OEMs letter head. However for service related issue the bidder will be solely responsible.
	<u>Tender No-UCO/SEC/HO/2021/179 Dated 31/03/2021.</u>	
4.	Fire Alarm panel (only for HO-I) Specification of Alarm panel <u>Annexure-G</u> Few things to be modified	a.-Armoured Cable-Should be FRLS type. b. Panel should be of UL-10 th edition. c. Approved Makes-Siemens (Addition)
5.	Clause No-4.C Fire Pump-(only for HO-I) one stand by diesel driven fire pump should be installed.	Stand by fire pump should be connected with the existing Diesel Generator.
6.	Clause No-4.4-B.(only for HO-I) <u>Modular Type Fire Extinguishers</u> Warranty & AMC-Not mentioned	Warranty Will Be 3 Yrs & AMC will be for next 3 yrs

In view of the above, all please note that, the relevant Clauses of both Tender documents should be treated as amended accordingly. The other terms & conditions will be remain unchanged.

AGM & Chief Security Officer





Corrigendum

Dt-13/04/2021

Ref No- i) e-Tender No-UCO/SEC/HO/2021/179 dated 31/03/2021.

ii) e-Tender No-UCO/SEC/HO/2021/180 dated 31/03/2021

Subsequent to Pre-bid meeting with the representatives of participating vendors held on 12/04/2021, at 11.30 hrs at Central Security Dept., Head Office, UCO Bank, 10, BTM Sarani, Kolkata-01, as per schedule given in the tenders under reference, as per queries raised by all vendors, the following amendments have been made in both Tenders documents -

SI No	Query Raised	Proposed Changes/ Amendment
	<u>Tender No-UCO/SEC/HO/2021/179 & 180 dated 31/03/2021.</u>	
1.	Clause- 5.3 (for both) Installation & Commissioning-Time given 8(eight) weeks.	Installation & Commissioning Time may be extended up to 10 (Ten) weeks after handing over the site to selected L-1 vendor.
2.	Part-IV-Scope of Work (for both) Submission of SLD- Not Mentioned	A sub-clause will be inserted that L-1 vendor will submit a Single Line Diagram after installation.
3.	Clause No-1.2- (for both) Contents of Technical Bid-Letter from OEM- Not Mentioned	MAF should be submitted by bidders in OEMs letter head. However for service related issue the bidder will be solely responsible.
	<u>Tender No-UCO/SEC/HO/2021/179 Dated 31/03/2021.</u>	
4.	Fire Alarm panel (only for HO-I) Specification of Alarm panel <u>Annexure-G</u> Few things to be modified	a.-Armoured Cable-Should be FRLS type. b. Panel should be of UL-10 th edition. c. Approved Makes-Siemens (Addition)
5.	Clause No-4.C Fire Pump-(only for HO-I) one stand by diesel driven fire pump should be installed.	Stand by fire pump should be connected with the existing Diesel Generator.
6.	Clause No-4.4-B (only for HO-I) <u>Modular Type Fire Extinguishers</u> Warranty & AMC-Not mentioned	Warranty Will Be 3 Yrs & AMC will be for next 3 yrs

In view of the above, all please note that, the relevant Clauses of both Tender documents should be treated as amended accordingly. The other terms & conditions will be remain unchanged.

AGM & Chief Security Officer

