

**Subject: 'Corrigendum' in Technical Specification and Extension of Tender Submission date & Part-I opening Date on the basis of Pre-Bid Meeting for Engagement of Agency towards Modernization of existing two nos 'schindler-make 5 Passenger Elevators installed at UCO Bank Building at UCO House,1/1 Alipore Avenue, Kolkata 700027 under buyback arrangement (RFP No. HO/GAD/ 420 /2021-22 Date: 25/05/2021).**

**Ref: Pre-Bid meeting held at UCO Bank H.O.GAD at 2<sup>nd</sup> Floor Head Office Building,10 B.T.M Sarani,Kolkata-700001. on 02.06.2021 at 15.00 Hours .**

**A) Amendments in - Technical Specification- ANNEXURE-VIII (page:50-51 of RFP)**

**Point No .4**

| Items                        | As specified in RFP   | Amendments                                    |
|------------------------------|---|---|
| <b>Machine Room Location</b> | Machine Room Less(MRL)  | Machine room(MR)                              |
| <b>Type of Control</b>       | Permanent Magnet AC Synchronous Motor (ECO Disc Gearless Motor) | <i>asynchronous induction motor(Gearless)</i> |
| <b>Load &amp; Capacity</b>   | 408 kg or 06 persons  | <i>5 passenger, 340Kgs.</i>                   |
| <b>Clear opening</b>         | 700 mm wide x 2000 mm height                                    | 750 mm wide x 2000 mm height                  |
| <b>Door type</b>             | Two-panel centre opening Plain Panel (COPD), Single Entrance    | Opening (Left or Right) Single Entrance       |

# यूको बैंक



# UCO BANK

सम्मान आपके विश्वास का

Honours your trust

|                              |   |  |
|------------------------------|---|--|
| <b>Car Operating Panel</b>   | 7 Segment Stainless Steel LCD display Square surface mounted Buttons with braille | 7 Segment Stainless Steel LCD display Square surface mounted LED touch sensitive |
| <b>Landing Signalization</b> | 7 Segment Stainless Steel display with braille                                    | 7 Segment Stainless Steel display LED touch sensitive                            |

## Point No .3.V

| Items                 | As specified in RFP   | Amendment  |
|-----------------------|---|--|
| <b>Traction Media</b> | Replacement of Existing Traction Ropes by STM(Suspension Traction Media) belt. – 2000 Mtrs./job | Replacement of Existing Traction Ropes by STM(Suspension Traction Media) belt/Rope. – 2000 Mtrs./job |

# यूको बैंक



# UCO BANK

सम्मान आपके विश्वास का

Honours your trust

## B) Amendments in - Notice Inviting Tender- (page:3-6 of RFP)

| Items   | As specified in RFP  | Amendments   |
|---|--|--|
| <b>Last Date &amp; Time for Submission of Tender</b>        | Bids can be submitted online before <b>15/06/2021</b> upto 12:00 pm at e-Tender website <a href="http://www.tenderwizard.in/UCOBANK">www.tenderwizard.in/UCOBANK</a> .                       | Bids can be submitted online before <b>25/06/2021</b> upto 12:00 pm at e-Tender website <a href="http://www.tenderwizard.in/UCOBANK">www.tenderwizard.in/UCOBANK</a> .                       |
|   | Off line original hard copy of Part-I of tender document to be submitted <b>18/06/2021</b> upto 4:00 PM at UCO Bank, GAD, Head Office at 2 <sup>nd</sup> Floor,10 BTM sarani, Kolkata-700001 | Off line original hard copy of Part-I of tender document to be submitted <b>28/06/2021</b> upto 4:00 PM at UCO Bank, GAD, Head Office at 2 <sup>nd</sup> Floor,10 BTM sarani, Kolkata-700001 |
| <b>Date and Time of Opening of Technical Bid i.e Part-I</b> | <b>15/06/2021</b> at 2:30 PM at UCO Bank, GAD, Head Office at 2 <sup>nd</sup> Floor,10 BTM sarani, Kolkata-700001  | <b>25/06/2021</b> at 2:30 PM at UCO Bank, GAD, Head Office at 2 <sup>nd</sup> Floor,10 BTM sarani, Kolkata-700001  |

Asst.General Manager(HO-GAD)