

**CORRIGENDUM -2**

Regarding our replacement of 3 lifts with new ones for UCO Bank, GAD , Zonal Office, 5-Parliament street. New Delhi, in price bid, we herein submit corrigendum 2, as per queries received:

- 1) Total no of floors for lift functioning shall be G+4, and not G+5.
- 2) Operations shall be Duplex/simplex as per site conditions.
- 3) Vision panel in lift doors not required. There shall be no compromise regarding fire safety norms.
- 4) Temporary wiring shall be provided by contractor, however double earthing, Elcb/Rccb shall be in banks

The dates for opening up of bids be extended by one week and the last date of receiving bids will be 22.12.2017 now.

---

सामान्य प्रशासन विभाग, यूको बैंक, अंचल कार्यालय, 5, संसद मार्ग, नई दिल्ली - 110001

General Administration Dept., UCO Bank, Zonal Office, 5, Sansad Marg, New Delhi -110001

फोन Phone: 011-49498247

ई मेल-E-mail: [zo.newdelhi.gad@ucobank.co.in](mailto:zo.newdelhi.gad@ucobank.co.in)