



**UCO BANK**  
**Department of Information Technology**

**Request for Proposal (RFP) for Supply, Installation & Maintenance of 2 Nos. of 40 KVA UPS**

**RFP Ref. No: UCO/DIT/3836/2021-22 Date: 29.01.2022**

**Pre-Bid Responses/ Clarifications to Queries raised by the Bidder(s)**

Sl. No	Page No	Clause No	Clause as per RFP	Description of Query/ Clarification sought by Bidder	Bank Response
1.	22	31	Submission of Offer-Three Bid System	Clarification of submission chart	RFP clause is self-explanatory. For further clarifications please refer diagram given in RFP page 24.
2.	98	14	The UPS System should be – a) Generator Compatible b) Generator Rating should not exceed 1.5 times of the UPS Rating c) should have input isolation transformer	Inbuilt output isolation transformer will be provided	Clause stands as per RFP
3.	99	24	Efficiency - Overall : $\geq 96\%$ (at full load)	93% considering inbuilt output transformer	Clause stands as per RFP
4.	99	27	Noise level (at 1 meter from the UPS) : 1 - $<55$ dBA @ 1meter	$<65$ dBA	Clause stands as per RFP
5.	100	28	The Battery Charger: - Must have transformer rectifier combination with protection against overcharges	Inbuilt output isolation transformer will be provided	Clause stands as per RFP

6.	103	40	Acceptance Test Testing of UPS Should be carried out in the ratio of 1:15 where volume is >100; 1:10 where volume is 16-99 & 1:5 i where volume is 5 -15 from any one of the testing centers of the Department of Electronics, Govt. of India, or such other testing centers approved by Govt. of India with prior approval from the Appropriate Authority. In the event of purchase of a single UPS the same shall be subject to Testing. The testing shall be conducted with reference to the specifications	Factory test report will be submitted	Clause stands as per RFP
7.	22	31	Eligibility evaluation would be completed first followed by Technical & Functional valuation. Thereafter, Price Information (Commercial Bid) of the eligible & technically qualified bidders will be opened and Lowest Bidder (L1) will be selected based on the Total Amount quoted in the commercial bid	Request you to please clarify that L1 will be decided on the Total Amount Quoted in the Commercial i.e "Total Cost in Table A + Total Cost in Table B". After the evaluation of the Eligibility and Technical bid	Yes, L1 bidder will be decided on total cost of ownership i.e. total cost in table A + total cost in table B.

**Date- 09.02.2022**

**Place-Kolkata**